

Pine Tree Elementary School - Water Testing - February 26, 2021

Room	Source	Result	Action
Kitchen	Kitchen sink #3	17.8 ug/m	Posted: "Do Not Drink"
Kitchen	Kitchen faucet	16.7 ug/m	Posted: "Do Not Drink"
Kitchen	Bathroom sink	18 ug/m	Posted: "Do Not Drink"
Library	Kitchen sink	54.9 ug/m	Posted: "Do Not Drink"
500 Wing Faculty	Bathroom sink	28.4 ug/m	Posted: "Do Not Drink"
Room 501	Classroom sink	38.5 ug/m	Posted: "Do Not Drink"
Room 501	Water Fountain	54.3 ug/m	Posted: "Do Not Drink"
Room 503	Classroom sink	33.5 ug/m	Posted: "Do Not Drink"
Room 505	Classroom sink	26.9 ug/m	Posted: "Do Not Drink"
Room 505	Water fountain	17.4 ug/m	Posted: "Do Not Drink"
Room 507	Classroom sink	54.2 ug/m	Posted: "Do Not Drink"
Room 509	Classroom sink	27.6 ug/m	Posted: "Do Not Drink"
Room 511	Classroom sink	24.8 ug/m	Posted: "Do Not Drink"
Room 513	Classroom sink	24.9 ug/m	Posted: "Do Not Drink"
Room 515	Classroom sink	68.6 ug/m	Posted: "Do Not Drink"
Room 515	Water fountain	76.7 ug/m	Posted: "Do Not Drink"
Room 517	Classroom sink	35.7 ug/m	Posted: "Do Not Drink"
Room 517	Water fountain	16.6 ug/m	Posted: "Do Not Drink"
Room 512	Classroom sink	15.7 ug/m	Posted: "Do Not Drink"
Room 512	Water fountain	30.1 ug/m	Posted: "Do Not Drink"
Room 510	Classroom sink	51.6 ug/m	Posted: "Do Not Drink"
Room 501	Classroom sink	40.6 ug/m	Posted: "Do Not Drink"
Room 501	Water fountain	106 ug/m	Posted: "Do Not Drink"
Room 506	Classroom sink	39.2 ug/m	Posted: "Do Not Drink"
Room 506	Water fountain	32.7 ug/m	Posted: "Do Not Drink"

500 Wing Girls	Bathroom sink #1	17.2 ug/m	Posted: "Do Not Drink"
500 Wing Girls	Bathroom sink #2	27.4 ug/m	Posted: "Do Not Drink"
500 Wing Girls	Bathroom sink #3	109 ug/m	Posted: "Do Not Drink"
500 Wing Girls	Bathroom sink #4	30.9 ug/m	Posted: "Do Not Drink"
500 Wing Boys Gym	Bathroom sink #1	17.7 ug/m	Posted: "Do Not Drink"
500 Wing Boys Gang	Bathroom sink #2	48 ug/m	Posted: "Do Not Drink"
500 Wing Boys Gang	Bathroom sink #3	29 ug/m	Posted: "Do Not Drink"
500 Wing Boys Gang	Bathroom sink #4	41.6 ug/m	Posted: "Do Not Drink"
Room 504	Classroom sink	103 ug/m	Posted: "Do Not Drink"
Room 504	Water fountain	61.5 ug/m	Posted: "Do Not Drink"
Room 502	Classroom sink	27 ug/m	Posted: "Do Not Drink"
Room 500	Classroom sink	92.2 ug/m	Posted: "Do Not Drink"
Room 500	Water fountain	19 ug/m	Posted: "Do Not Drink"
Public Area Womens BS-2	Bathroom sink	25.8 ug/m	Posted: "Do Not Drink"
Public Area Mens BS-1	Bathroom sink	20.2 ug/m	Posted: "Do Not Drink"
Public Area Mens BS-2	Bathroom sink	29.2 ug/m	Posted: "Do Not Drink"
Room 301	Water fountain	30.4 ug/m	Posted: "Do Not Drink"
Room 301	Bathroom sink	48.4 ug/m	Posted: "Do Not Drink"
Room 303	Bathroom sink	24.9 ug/m	Posted: "Do Not Drink"
Room 303	Water fountain	182 ug/m	Posted: "Do Not Drink"
Room 305	Water fountain	35.9 ug/m	Posted: "Do Not Drink"
Room 305	Classroom sink	78.7 ug/m	Posted: "Do Not Drink"
Room 307	Bathroom sink	46.2 ug/m	Posted: "Do Not Drink"
Room 309	Water fountain	74.2 ug/m	Posted: "Do Not Drink"
Room 309	Bathroom sink	18 ug/m	Posted: "Do Not Drink"
Room 310	Classroom sink	22.3 ug/m	Posted: "Do Not Drink"
Room 310	Water fountain	47.4 ug/m	Posted: "Do Not Drink"

Room 310	Bathroom sink	48.9 ug/m	Posted: "Do Not Drink"
Room 308	Water fountain	89.5 ug/m	Posted: "Do Not Drink"
Room 308	Bathroom sink	30.5 ug/m	Posted: "Do Not Drink"
Room 306	Bathroom sink	36.1 ug/m	Posted: "Do Not Drink"
Room 306	Water fountain	21.6 ug/m	Posted: "Do Not Drink"
Room 306	Classroom sink	89.7 ug/m	Posted: "Do Not Drink"
Room 304	Bathroom sink	15.2 ug/m	Posted: "Do Not Drink"
Room 304	Classroom sink	77.9 ug/m	Posted: "Do Not Drink"
Room 302	Bathroom sink	34.3 ug/m	Posted: "Do Not Drink"
Room 302	Water fountain	29.5 ug/m	Posted: "Do Not Drink"
Room 302	Classroom sink	52.6 ug/m	Posted: "Do Not Drink"
Room 300	Classroom sink	93 ug/m	Posted: "Do Not Drink"
300 Wing Teachers	Bathroom sink	18.5 ug/m	Posted: "Do Not Drink"
Principal's Office	Bathroom sink	161 ug/m	Posted: "Do Not Drink"
Assistant Principal's	Bathroom sink	30.1 ug/m	Posted: "Do Not Drink"
Faculty Room 100 Women's	Bathroom sink	17 ug/m	Posted: "Do Not Drink"
Faculty Room 100 Men's	Bathroom sink	75.6 ug/m	Posted: "Do Not Drink"
Nurse's BS	Bathroom sink	62 ug/m	Posted: "Do Not Drink"
Nurse	Sink #1	26.8 ug/m	Posted: "Do Not Drink"
Nurse	Sink #2	27.8 ug/m	Posted: "Do Not Drink"
Nurse	Sink #3	126 ug/m	Posted: "Do Not Drink"
Room 200A	Classroom sink	156 ug/m	Posted: "Do Not Drink"
Room 201	Classroom sink	26.4 ug/m	Posted: "Do Not Drink"
Room 202	Classroom sink	58.3 ug/m	Posted: "Do Not Drink"
Room 203	Classroom sink	41.4 ug/m	Posted: "Do Not Drink"
Room 204	Classroom sink	35 ug/m	Posted: "Do Not Drink"
Room 205	Classroom sink	29 ug/m	Posted: "Do Not Drink"

200 Wing Girls	Bathroom sink #2	18.5 ug/m	Posted: "Do Not Drink"
200 Wing Women's Faculty	Bathroom sink	16.5 ug/m	Posted: "Do Not Drink"
200 Wing Boys	Bathroom sink #1	17.5 ug/m	Posted: "Do Not Drink"
200 Wing Men's Faculty	Bathroom sink	121 ug/m	Posted: "Do Not Drink"
Room 207	Classroom sink	18.3 ug/m	Posted: "Do Not Drink"
Room 206	Classroom sink	50.3 ug/m	Posted: "Do Not Drink"
Room 209	Classroom sink	31.9 ug/m	Posted: "Do Not Drink"
Room 208	Classroom sink	25.7 ug/m	Posted: "Do Not Drink"
Room 211	Classroom sink	58.5 ug/m	Posted: "Do Not Drink"
Room 213	Bathroom sink	68.4 ug/m	Posted: "Do Not Drink"
Room 210	Bathroom sink	51.5 ug/m	Posted: "Do Not Drink"
Room 210	Classroom sink	59.2 ug/m	Posted: "Do Not Drink"
Gym Boys	Bathroom sink #2	45.7 ug/m	Posted: "Do Not Drink"
Men's Coaches	Bathroom sink	475 ug/m	Posted: "Do Not Drink"
Women's Coaches	Bathroom sink	48.4 ug/m	Posted: "Do Not Drink"
Gym Girls Locker Room	Water fountain	71.6 ug/m	Posted: "Do Not Drink"
Gym Girls Locker Room	Bathroom sink #1	22.9 ug/m	Posted: "Do Not Drink"
Gym Girls Locker Room	Bathroom sink #2	71.2 ug/m	Posted: "Do Not Drink"
Room 109	Classroom sink	57.8 ug/m	Posted: "Do Not Drink"
Room 107	Classroom sink	46.1 ug/m	Posted: "Do Not Drink"
Room 106	Classroom sink	88 ug/m	Posted: "Do Not Drink"
Room 105	Classroom sink	28.6 ug/m	Posted: "Do Not Drink"
Room 104	Classroom sink	61.8 ug/m	Posted: "Do Not Drink"
100 Wing Girls Gang BS 1	Bathroom sink #1	21 ug/m	Posted: "Do Not Drink"
100 Wing Girls Gang BS 2	Bathroom sink #2	35 ug/m	Posted: "Do Not Drink"
100 Wing Girls Gang BS 3	Bathroom sink #3	16.7 ug/m	Posted: "Do Not Drink"
100 Wing Women's Faculty	Bathroom sink	44.2 ug/m	Posted: "Do Not Drink"

Room 103	Classroom sink	40.8 ug/m	Posted: "Do Not Drink"
Room 102	Classroom sink	47.1 ug/m	Posted: "Do Not Drink"
Room 101	Classroom sink	26.5 ug/m	Posted: "Do Not Drink"
Room 100	Classroom sink	156 ug/m	Posted: "Do Not Drink"
Room 99	Classroom sink	64.9 ug/m	Posted: "Do Not Drink"