

Sapphire Elementary School - Water Testing - February 23, 2021

| Room | Source | Result | Action |
|-----------|------------------------------|-----------|-----------------------|
| Room 111 | teacher's kitchen sink | 168 ug/L | Posted "do not drink" |
| Room 111A | bathroom sink | 24.2 ug/L | Posted "do not drink" |
| Room 115 | bathroom sink | 138 ug/L | Posted "do not drink" |
| Room 104 | bathroom sink | 36.9 ug/L | Posted "do not drink" |
| Room 102 | bathroom sink | 15.9 ug/L | Posted "do not drink" |
| Room 101 | bathroom sink | 70.5 ug/L | Posted "do not drink" |
| Room 100E | girls' bathroom sink | 25.4 ug/L | Posted "do not drink" |
| Room 100B | boys' bathroom sink | 19.1 ug/L | Posted "do not drink" |
| Room 204 | classroom sink | 24.4 ug/L | Posted "do not drink" |
| Room 213B | girls' bathroom sink #1 | 18.2 ug/L | Posted "do not drink" |
| Room 213B | girls' bathroom sink #2 | 18.4 ug/L | Posted "do not drink" |
| Room 203 | classroom sink | 81 ug/L | Posted "do not drink" |
| Room 205 | bathroom sink | 15.1 ug/L | Posted "do not drink" |
| Room 122 | classroom sink #2 | 22 ug/L | Posted "do not drink" |
| Room 207 | classroom sink | 25.6 ug/L | Posted "do not drink" |
| Room 122 | classroom sink #2 | 54.3 ug/L | Posted "do not drink" |
| Room 109 | Nurse's office bathroom sink | 15.2 ug/L | Posted "do not drink" |