

Monroe-Woodbury CSD Central Valley Action Locations 3/12/2021

Room	Source	Result	Remediation
Room 500	Kitchen Sink	17.80 ug/L	Posted: "Do Not Drink"
Room 505	Classroom Sink	23.10 ug/L	Posted: "Do Not Drink"
Room 504	Classroom Sink	29.20 ug/L	Posted: "Do Not Drink"
Room 404	Classroom Sink	29.20 ug/L	Posted: "Do Not Drink"
Kitchen	Kitchen Sink #2	23.90 ug/L	Posted: "Do Not Drink"
Library Kitchen	Kitchen Sink	35.90 ug/L	Posted: "Do Not Drink"
Kitchen	Kitchen Sink #3	19.80 ug/L	Posted: "Do Not Drink"
Coaches Office Womens	Bathroom Sink	22.00 ug/L	Posted: "Do Not Drink"
Ref Room	Bathroom Sink	68.80 ug/L	Posted: "Do Not Drink"
Ref Room	Bubbler/Water Fountain	23.30 ug/L	Posted: "Do Not Drink"
Coaches Men	Bathroom Sink	40.40 ug/L	Posted: "Do Not Drink"
Locker Room	Bathroom Sink	16.80 ug/L	Posted: "Do Not Drink"
Room 206	Classroom Sink #4	17.00 ug/L	Posted: "Do Not Drink"
Kitchen	Kitchen Sink #4	16.50 ug/L	Posted: "Do Not Drink"
Room 221	Classroom Sink	25.30 ug/L	Posted: "Do Not Drink"
Kitchen	Spigot	21.20 ug/L	Posted: "Do Not Drink"
Rm 203 CS603 Rm 204 BS Results were reported incorrectly. For these 2 locations, retesting has been completed but results are not yet available. Both have been posted "Do Not Drink" pending results.			
Room 203	Classroom Sink		Posted: "Do Not Drink"
Room 204	Bathroom Sink		Posted: "Do Not Drink"