

Monroe-Woodbury Middle School Water Testing Results - March 11, 2021

Room	Source	Result	Remediation
Kitchen	Kitchen Sink #1	19.2 ug/L	Posted: "Do Not Drink"
Outside Room 117A Women's Bathroom	Bathroom sink	23.4 ug/L	Posted: "Do Not Drink"
Outside Room 238 Girls Bathroom	Bathroom sink #4	24.9 ug/L	Posted: "Do Not Drink"
Room 238	Classroom sink	42.4 ug/L	Posted: "Do Not Drink"
Room 243	Classroom sink	22.1 ug/L	Posted: "Do Not Drink"
Prep Room 200	Classroom sink #1	87.7 ug/L	Posted: "Do Not Drink"
Outside Room 207 Bathroom	Bathroom sink #1	24.8 ug/L	Posted: "Do Not Drink"
Outside Room 207 Girls Bathroom	Bathroom sink #1	15.5 ug/L	Posted: "Do Not Drink"
Outside Room 207 Girls Bathroom	Bathroom sink #2	19.3 ug/L	Posted: "Do Not Drink"
Outside Room 207 Girls Bathroom	Bathroom sink #3	18.9 ug/L	Posted: "Do Not Drink"
Outside Room 207 Boys Bathroom	Bathroom sink #1	18.6 ug/L	Posted: "Do Not Drink"
Outside Room 207 Boys Bathroom	Bathroom sink #2	24.8 ug/L	Posted: "Do Not Drink"
Outside Room 207 Boys Bathroom	Bathroom sink #3	18.7 ug/L	Posted: "Do Not Drink"
Outside Room 116A Women's Bathroom	Bathroom sink #3	63.3 ug/L	Posted: "Do Not Drink"
Prep Room 206	Classroom sink	93.3 ug/L	Posted: "Do Not Drink"
Nurse	Bathroom sink #1	24.5 ug/L	Posted: "Do Not Drink"
Nurse Office	Bathroom sink	15.1 ug/L	Posted: "Do Not Drink"
Outside Room 116A Men Bathroom	Bathroom sink #1	31.7 ug/L	Posted: "Do Not Drink"
Outside Room 116A Men Bathroom	Bathroom sink #2	20.4 ug/L	Posted: "Do Not Drink"
Outside Room 116A Men Bathroom	Bathroom sink #3	15.6 ug/L	Posted: "Do Not Drink"
Room 115	Classroom sink #1	25.7 ug/L	Posted: "Do Not Drink"
Room 115	Classroom sink #2	31.9 ug/L	Posted: "Do Not Drink"
Library Faculty Bathroom	Bathroom sink #1	20.9 ug/L	Posted: "Do Not Drink"
Kitchen	Kitchen Sink #2	15.6 ug/L	Posted: "Do Not Drink"
Library Faculty Bathroom	Bathroom sink #2	16.4 ug/L	Posted: "Do Not Drink"
Library Mail Room	Kitchen Sink	31.3 ug/L	Posted: "Do Not Drink"
Library Office	Kitchen Sink	50.4 ug/L	Posted: "Do Not Drink"
Room 155	Kitchen Sink	16.5 ug/L	Posted: "Do Not Drink"
Guidance	Kitchen Sink	28.8 ug/L	Posted: "Do Not Drink"
Pool Locker Room Girls Bathroom	Bathroom sink #1	30.3 ug/L	Posted: "Do Not Drink"
Pool Locker Room Girls Bathroom	Bathroom sink #2	33.1 ug/L	Posted: "Do Not Drink"
Coaches Men's Bathroom Pool	Bathroom sink	33.7 ug/L	Posted: "Do Not Drink"
Pool Locker Room Boys Bathroom	Bathroom sink #1	33.1 ug/L	Posted: "Do Not Drink"
Pool Locker Room Boys Bathroom	Bathroom sink #2	61.2 ug/L	Posted: "Do Not Drink"

Pool Locker Room Boys Handicap Bathroom	Bathroom sink #1	18.0 ug/L	Posted: "Do Not Drink"
Kitchen Dish Room	Kitchen sink	32.3 ug/L	Posted: "Do Not Drink"
Pool Locker Room Boys Handicap Bathroom	Bathroom sink #2	35.1 ug/L	Posted: "Do Not Drink"
Locker Room Girls Bathroom	Bathroom sink #1	15.9 ug/L	Posted: "Do Not Drink"
Locker Room Girls Bathroom	Bathroom sink #2	28.7 ug/L	Posted: "Do Not Drink"
Locker Room Girls Bathroom	Bathroom sink #3	18.2 ug/L	Posted: "Do Not Drink"
Coaches Women's Bathroom	Bathroom sink	22.4 ug/L	Posted: "Do Not Drink"
OT/PT Room	Bathroom sink #1	66.9 ug/L	Posted: "Do Not Drink"
OT/PT Room	Bathroom sink #2	34.4 ug/L	Posted: "Do Not Drink"
Pool Men's Bathroom	Bathroom sink	25.7 ug/L	Posted: "Do Not Drink"
Pool Women's Bathroom	Bathroom sink	18.7 ug/L	Posted: "Do Not Drink"
Outside Gym Girls Bathroom	Bathroom sink #2	18.8 ug/L	Posted: "Do Not Drink"
Outside Gym Girls Bathroom	Bathroom sink #3	17.9 ug/L	Posted: "Do Not Drink"
Outside Gym Boys Bathroom	Bathroom sink #1	16.7 ug/L	Posted: "Do Not Drink"
Outside Gym Boys Bathroom	Bathroom sink #2	22.1 ug/L	Posted: "Do Not Drink"
Outside Gym Boys Bathroom	Bathroom sink #3	22.1 ug/L	Posted: "Do Not Drink"
Outside Gym Boys Bathroom	Bathroom sink #4	16.7 ug/L	Posted: "Do Not Drink"
Boys Locker Room	Bathroom sink #1	28.1 ug/L	Posted: "Do Not Drink"
Boys Locker Room	Bathroom sink #2	27.0 ug/L	Posted: "Do Not Drink"
Boys Locker Room	Bathroom sink #3	50.1 ug/L	Posted: "Do Not Drink"
Kitchen	Fountain/Sink	17.7 ug/L	Posted: "Do Not Drink"
Coaches Men's Bathroom	Bathroom sink #2	37.4 ug/L	Posted: "Do Not Drink"
Coaches Men's Bathroom	Bathroom sink #3	38.7 ug/L	Posted: "Do Not Drink"
Weight Room	H/Sink	39.9 ug/L	Posted: "Do Not Drink"
Room 127	Classroom sink	43.4 ug/L	Posted: "Do Not Drink"
Room 126	Kitchen sink #3	15.3 ug/L	Posted: "Do Not Drink"
Room 139B	Classroom sink	24.0 ug/L	Posted: "Do Not Drink"
Room 140B	Classroom sink	33.8 ug/L	Posted: "Do Not Drink"
Room 140A	Classroom sink	434 ug/L	Posted: "Do Not Drink"
Room 141A	Classroom sink	43.0 ug/L	Posted: "Do Not Drink"
Instrument Storage	Classroom sink	32.3 ug/L	Posted: "Do Not Drink"
Room 138A	Classroom sink	40.3 ug/L	Posted: "Do Not Drink"
Room 224	Classroom sink	16.2 ug/L	Posted: "Do Not Drink"
Room 226A	Classroom sink	34.2 ug/L	Posted: "Do Not Drink"
Outside Room 117A Men's Bathroom	Bathroom sink	26.4 ug/L	Posted: "Do Not Drink"
Room 225	Classroom sink	134 ug/L	Posted: "Do Not Drink"

Room 226B	Classroom sink	35.3 ug/L	Posted: "Do Not Drink"
Room 228	Classroom sink	103 ug/L	Posted: "Do Not Drink"
Room 227	Classroom sink	36.9 ug/L	Posted: "Do Not Drink"
Outside Room 233 Boys Bathroom	Bathroom sink #1	19.0 ug/L	Posted: "Do Not Drink"