

Smith Clove Elementary School - Water Testing - March 4, 2021

Room	Source	Result	Action
E S O	Classroom sink	18.5 ug/L	Posted: "Do Not Drink"
Kitchen	Kitchen Sink 1	16.8 ug/L	Posted: "Do Not Drink"
Kitchen	Kitchen Sink 4	60.1 ug/L	Posted: "Do Not Drink"
Custodial Office	Bathroom sink	22.4 ug/L	Posted: "Do Not Drink"
Lower Level Boys Bathroom	Bathroom sink #3	25.8 ug/L	Posted: "Do Not Drink"
Lower Level Girls Bathroom	Bathroom sink #2	28.1 ug/L	Posted: "Do Not Drink"
Room 002	Classroom sink	172 ug/L	Posted: "Do Not Drink"
Room 105	Classroom sink	18.9 ug/L	Posted: "Do Not Drink"
Room 106	Classroom sink	20.5 ug/L	Posted: "Do Not Drink"
Room 103	Classroom sink	17.9 ug/L	Posted: "Do Not Drink"
Room 102	Bathroom sink	34.2 ug/L	Posted: "Do Not Drink"
Room 110	Classroom sink	43.3 ug/L	Posted: "Do Not Drink"
Room 109	Classroom sink	109 ug/L	Posted: "Do Not Drink"
Room 109	Water fountain/bubbler	15.9 ug/L	Posted: "Do Not Drink"
Room 113	Classroom sink	34.6 ug/L	Posted: "Do Not Drink"
2nd Floor Boys Bathroom	Bathroom sink #3	15.1 ug/L	Posted: "Do Not Drink"
2nd Floor Girls Bathroom	Bathroom sink #2	15.3 ug/L	Posted: "Do Not Drink"
Room 003	Classroom sink	16.4 ug/L	Posted: "Do Not Drink"
Room 210	Classroom sink	34.4 ug/L	Posted: "Do Not Drink"
Room 210	Water fountain/bubbler	15.1 ug/L	Posted: "Do Not Drink"
Room 209	Classroom sink	22.8 ug/L	Posted: "Do Not Drink"
Room 211	Classroom sink	20.8 ug/L	Posted: "Do Not Drink"
Room 211	Water fountain/bubbler	26.5 ug/L	Posted: "Do Not Drink"
Room 214	Classroom sink	17.7 ug/L	Posted: "Do Not Drink"
Room 213	Classroom sink	82.2 ug/L	Posted: "Do Not Drink"
Room 208	Classroom sink	18.7 ug/L	Posted: "Do Not Drink"
Room 208	Water fountain/bubbler	21 ug/L	Posted: "Do Not Drink"
Room 205	Classroom sink	17 ug/L	Posted: "Do Not Drink"
Room 205	Water fountain/bubbler	38.1 ug/L	Posted: "Do Not Drink"
Room 004	Classroom sink	27.5 ug/L	Posted: "Do Not Drink"
Room 206	Classroom sink	28.7 ug/L	Posted: "Do Not Drink"
Room 204	Classroom sink	53.4 ug/L	Posted: "Do Not Drink"
Room 204	Water fountain/bubbler	169 ug/L	Posted: "Do Not Drink"
Room 203	Classroom sink	87.5 ug/L	Posted: "Do Not Drink"
Room 201	Classroom sink	15.7 ug/L	Posted: "Do Not Drink"
Occ./Phys. Therapy	Classroom sink	80 ug/L	Posted: "Do Not Drink"

