

Monroe-Woodbury CSD High School Water Sampling 6/15/2021

Location	Fixture	Result	Remediation
Large Kitchen	Kitchen Sink #2	19.4 µg/l	Posted: "Do Not Drink"
Large Kitchen	Kitchen Sink #3	9.05 µg/l	
Large Kitchen	Kitchen Sink #4	12.2 µg/l	
Near Barrel Washer	Hand washing station	1.9 µg/l	