

Monroe-Woodbury CSD Middle School Water Sampling 6/18/2021

Location	Source	Result	Remediation
Girls Pool Locker Room	Bathroom Sink #1	18.9 µg/l	Posted: "Do Not Drink"
Girls Pool Locker Room	Bathroom Sink #2	16.5 µg/l	Posted: "Do Not Drink"
Pool Coaches Mens	Bathroom Sink #3	16.4 µg/l	Posted: "Do Not Drink"
Pool Boys Locker Room	Bathroom Sink #2	17.6 µg/l	Posted: "Do Not Drink"
Pool Mens	Bathroom Sink #2	15.1 µg/l	Posted: "Do Not Drink"
OTPT	Bathroom Sink #1	26.4 µg/l	Posted: "Do Not Drink"
OTPT	Bathroom Sink #2	15.1 µg/l	Posted: "Do Not Drink"
Boys Locker Room	Bathroom Sink #3	17.8 µg/l	Posted: "Do Not Drink"
Weight Room	Hose Spigot	1020 µg/l	Posted: "Do Not Drink"
Across from Gym Boys	Bathroom Sink #3	21.9 µg/l	Posted: "Do Not Drink"
Across from Gym Girls	Bathroom Sink #2	18.8 µg/l	Posted: "Do Not Drink"
Room 138A	Classroom Sink	17.1 µg/l	Posted: "Do Not Drink"
Room 140A	Classroom Sink	16.8 µg/l	Posted: "Do Not Drink"
Instrument Storage	Classroom Sink	17.7 µg/l	Posted: "Do Not Drink"
O/S 16A Womens	Bathroom Sink #3	15.9 µg/l	Posted: "Do Not Drink"
Room 115	Classroom Sink #2	20.9 µg/l	Posted: "Do Not Drink"
Room 224	Classroom Sink	16.8 µg/l	Posted: "Do Not Drink"
Room 226A	Classroom Sink	25.9 µg/l	Posted: "Do Not Drink"
Room 225	Classroom Sink	24.7 µg/l	Posted: "Do Not Drink"
Room 226B	Classroom Sink	30.9 µg/l	Posted: "Do Not Drink"
Room 228	Classroom Sink	58.8 µg/l	Posted: "Do Not Drink"
Room 227	Classroom Sink	28.5 µg/l	Posted: "Do Not Drink"
O/S 238 Girls	Bathroom Sink #4	72.6 µg/l	Posted: "Do Not Drink"
Room 238	Classroom Sink	41.1 µg/l	Posted: "Do Not Drink"
Room 243	Classroom Sink	18.4 µg/l	Posted: "Do Not Drink"
Room 200	Prep Room Sink	118 µg/l	Posted: "Do Not Drink"
Room 206	Prep Room Sink	33.7 µg/l	Posted: "Do Not Drink"
O/S 207	Bathroom Sink #1	18.7 µg/l	Posted: "Do Not Drink"
Guidance	Kitchen Sink	17.1 µg/l	Posted: "Do Not Drink"